



The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards include enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

The City of Big Spring Water Treatment Plant failed to meet the minimum treatment technique requirements for the month of January, 2010. Specifically, our water system allowed the turbidity of the filtered water to exceed 0.3 Nephelometric Turbidity Units in more than 5.0 percent of the measurements made during the month.

This violation is classified as a non-acute violation. The City is addressing the issues that contributed to the cause of the violation and will continue to work towards providing you the best quality product possible. If you want more information about the nature and significance of these violations, you may contact Kenny Scott at 264-2393 or Todd Darden at 264-2501.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses.) You can do this by posting this notice in a public place or distributing copies by hand or mail.